

KEY NOTES: (cont'd.)

N017 IN TOILETS, PROVIDE 120V, 20A RECEPTACLE UNDER EACH SINK, 12" BELOW COUNTER, FOR USE WITH FAUCET MOTION DETECTOR. OBTAIN POWER FROM GFI RECEPT ABOVE COUNTER. COORDINATE INSTALLATION WITH OTHER TRADES.

N018 AT EACH UNIT HEATER INSTALL VENDOR-FURNISHED T'STAT. SEE DET 6/E8.11.43.

N019 PROVIDE 120V TO MOTORIZED DAMPERS FROM NEAREST RECEPT. SEE MECH DWGS.

N020 PROVIDE 120V TO DOOR CARD READER FROM CN-PANEL 2PPB-1. PROVIDE 3/4" C AND WIRING FROM DOOR POWER SUPPLY UG TO HANDICAPPED ACCESS BOLLARD OUTSIDE BLDG. SEE DETAIL 2/E8.11.42. COORDINATE INSTALLATION WITH OTHER TRADES AND WITH CM.



DCN CNMS-01